



Addressee :

**URSA IBERICA AISLANTES SA  
Ctra. Vilarodona km 6,7 Tarragona**

**43810 EL PLA DE SANTA MARIA  
ESPAGNE**

*For the attention of Mr Pedro URIZ*

Villeurbanne, 02/09/2005

Person in charge : **Anne TISSOT**

Signature :

**Test Report N° 2514088-temporary**

**Version : 00**

**TEST OF GLASSWOOOL DUCT ACCORDING TO EN  
13403**

EQUIPMENT ID : P5858 – P6058

MANUFACTURER : URSA IBERICA AISLANTES SA

REFERENCE DOCUMENT(S) : EN 13403

**CENTRE TECHNIQUE DES INDUSTRIES AÉRAULIQUES ET THERMIQUES**

---

*Mail address :* BP 2042 - 69603 Villeurbanne Cedex - France - Tél. +33 (0)4 72 44 49 00 - Fax. +33 (0)4 72 44 49 49  
*Address :* Domaine Scientifique de la Doua - 25, avenue des Arts - 69100 Villeurbanne  
*Delivery :* Domaine Scientifique de la Doua - 54, avenue Niels Bohr - 69100 Villeurbanne  
www.cetiat.fr - E. Mail : cetiat.commercial@cetiat.fr - Siret 775 686 967 00024 - Ape 731 Z

<b>Version</b>	<b>Date</b>	<b>Nature of change</b>	<b>Modified pages</b>
00	02/09/2005	First distributed	

**Each new version cancels and replaces the previous one.**

Results of test reports are the exclusive property of the customer and CETIAT prohibits their distribution to third parties without prior written consent.

Any commercial use of the name CETIAT or of test results is subject to CETIAT's prior consent.

This report may be reproduced only in its entirety.

The test reports written by CETIAT are valid only for the equipment provided for the test in the specific conditions under which the test was run.

Information concerning the measurement equipment used for the tests is kept in CETIAT's archives.

The use of these results for designing equipments using this material must take into account manufacturing tolerances and real operating conditions. CETIAT cannot be held liable for such use of these results.

The formulas or codes used to predict either the operation of a device in conditions other than those used in the test or the characteristics of similar devices of different dimensions are based on the state of knowledge at the time the results were delivered and are subject to change. The results obtained through these formulas or codes are given as an indication only.

The original copy of the report is given to the customer and a certified copy is kept at CETIAT.

***C O N T E N T S***

1. INTRODUCTION.....	4
2. SUMMARY OF THE RESULTS.....	5
APPENDIX 1 - REFERENCES .....	6
APPENDIX 2 - EROSION AND EMISSION OF PARTICLES .....	7
APPENDIX 3 - RESISTANCE AGAINST PRESSURE TEST .....	13
APPENDIX 4 - ARTIGHTNESS TEST.....	16
APPENDIX 5 - WEIGHTED ACOUSTICAL ABSORPTION TEST .....	22

## **1. INTRODUCTION**

The objective of the tests was to characterise two kinds of glasswool ducts according to EN 13403 July 2003 "Ventilation for buildings – Non-metallic ducts – Ductwork made from insulation ductboards". Tests were :

- Erosion and Emission of particles (§7.2 of EN 13403)
- Resistance against pressure (§7.3 of EN 13403)
- Air leakage factor and airtightness class (§4.3 of EN 13403, referred to §5.2 of prEN 1507)
- Weighted acoustical absorption (§4.7.7 of EN 13403, referred to ISO 354 and ISO 11654)

Two samples were tested :

- P5858 (inside of the ducts, glasswool is covered with airtightness aluminium) ;
- P6058 (inside of the ducts, glasswool is covered with microperforated aluminium).

Summary of the results is in part 2.

Detailed results of erosion and emission of particles tests are in appendix 2.

Detailed results of resistance against pressure tests are in appendix 3.

Detailed results of air leakage factor and airtightness class tests are in appendix 4.

Detailed results of weighted acoustical absorption tests are in appendix 5.

## 2. SUMMARY OF THE RESULTS

<b>EROSION AND EMISSION OF PARTICLES TEST</b>			
Air velocity = 18,6 m/s			
	Requirements	P5858	P6058
Particles > 0,5 µm	< 60 µg/m <sup>3</sup>	0,015	0,011
Particles > 5,0 µm	< 4,0 µg/m <sup>3</sup>	0,007	0,006

The material from the inside surface of the ductwork does not break away, flake off and does not show evidence of delamination or erosion.

<b>RESISTANCE AGAINST PRESSURE TEST</b>	
Pressure = 2000 Pa	
P5858	P6058
The clamps did not move during the test. At one place, adhesive tape begins to peel off. There is no evidence of damage, which would cause the sample to become unusable.	

<b>AIRTIGHTNESS TEST</b>				
	Pressure	P5858	Pressure	P6058
Leakage factor (l/s/m <sup>2</sup> )	-748 Pa	0,25	-746 Pa	0,38
Airtightness class		<b>B</b>		<b>B</b>
Leakage factor (l/s/m <sup>2</sup> )	1008 Pa	0,33	991 Pa	0,61
Airtightness class		<b>B</b>		<b>B</b>

<b>WEIGHTED ACOUSTICAL ABSORPTION TEST</b>		
	P5858	P6058
α <sub>w</sub>	0,45	0,50M

<b>APPENDIX 1 - REFERENCES</b>
--------------------------------

EN 13403-2003 : Ventilation for buildings – Non-metallic ducts – Ductwork made from insulation ductboards


ISO 11654-2002 : Acoustics – Rating of sound absorption – Materials and systems

ISO 354:2003 : Acoustics – Measurement of sound absorption in a reverberation room

PrEN 12237 : Ventilation for buildings – Ductwork – Strength and leakage of circular sheet metal ducts

**APPENDIX 2 - EROSION AND EMISSION OF PARTICLES**

The samples are arranged in an L-shaped assembly. The entire assembly has similar cross-section (300 mm \* 300 mm).



- |                      |                       |
|----------------------|-----------------------|
| 1 : Sucking box      | 5 : Blowing plenum    |
| 2 : Sucking fan      | 7 : Connexion duct    |
| 3 : Control valve    | 8 : Duct to be tested |
| 4 : Absolute filters |                       |

**Figure 1 : Construction for particle emission**

Tests consisted in :

- Purge during 1 h, air velocity = 12 m/s,
- Stop during 15 min,
- Erosion test during 5 h, air velocity = 18,6 m/s.

The particle accounting is made with an optical laser counter with different channels given in Table 1. The counting is not done during the purge.

Channel	Range
1	0,2 – 0,3 µm
2	0,3 – 0,5 µm
3	0,5 – 0,7 µm
4	0,7 – 1,0 µm
5	1,0 – 2,0 µm
6	2,0 – 3,0 µm
7	3,0 – 5,0 µm
8	> 5 µm

**Table 1 : Laser counter range**

The extracted flow rate is of 28,3 l/min.

The average particle concentration is calculated from the extracted air volume and the measurement of the particle's mass using the following formula :

$$C = \frac{M}{Q_v t}$$

Where :

C is the particle concentration in µg/m<sup>3</sup>,

M is the particles' mass in µg,

Q<sub>v</sub> is the extraction flow rate in m<sup>3</sup>/s.


The mass of particles is determined from the number of counted particles and the relative density of the glass (2500 kg/m<sup>3</sup>).




**Figure 2 : View of the test facility before the installation of the tested ducts**



**Figure 3 : Views of the installation with the tested ducts**



**Figure 4 : View of the inside of the P5858 sample**



**Figure 5 : View of the inside of the P6058 sample**

It can be seen in Figure 4 and Figure 5 that connections seem less tight for the P5858 sample than for the P6058 sample.

**Detailed results**

Duration of extraction for the optical laser counter : 315 minutes

Extracted flow rate for the optical laser counter : 28,3 l/min = 0,0283 m<sup>3</sup>/min

Extracted flow : 315 × 0,0283 = 8,91 m<sup>3</sup>

$$\text{Volume of a particle (diameter } d) = \frac{4}{3} \times \pi \times \left(\frac{d}{2}\right)^3$$

**P5858 sample**

Air velocity in the duct : 18,6 m/s

Air temperature : 21.8°C < T < 25.8°C

Range of particles diameter (µm)	Nb of counted particles	Nb of particles/m <sup>3</sup>	Particles mass in µg/m <sup>3</sup>
0,2 - 0,3	37344	4189.1	8.57E-05
0,3 - 0,5	26614	2985.5	2.50E-04
0,5 - 0,7	4165	467.2	1.32E-04
0,7 - 1,0	1504	168.7	1.36E-04
1,0 - 2,0	1285	144.1	6.37E-04
2,0 - 3,0	557	62.5	1.28E-03
3,0 - 5,0	331	37.1	3.11E-03
> 5,0	326	36.6	5.98E-03

**Table 2 : Detailed results of the erosion test – P5858 sample**

	Requirements	Test results
Particles > 0,5 µm	< 60 µg/m <sup>3</sup>	0,015
Particles > 5,0 µm	< 4,0 µg/m <sup>3</sup>	0,007

**Table 3 : Comparison with the requirements – P5858**

The material from the inside surface of the ductwork does not break away, flake off and does not show evidence of delamination or erosion.

**The requirements concerning the maximum particle concentration are fulfilled for the P5858 sample.**

**P6058 sample**

Air velocity in the duct : 18,6 m/s

Air temperature : 22.4°C < T < 24.7°C

Range of particles diameter (µm)	Nb of counted particles	Nb of particles/m <sup>3</sup>	Particles mass in µg/m <sup>3</sup>
0,2 - 0,3	58367	6547.4	1.34E-04
0,3 - 0,5	35953	4033.1	3.38E-04
0,5 - 0,7	3902	437.7	1.24E-04
0,7 - 1,0	1424	159.7	1.28E-04
1,0 - 2,0	1832	205.5	9.08E-04
2,0 - 3,0	884	99.2	2.03E-03
3,0 - 5,0	519	58.2	4.88E-03
> 5,0	396	44.4	7.27E-03

**Table 4 : Detailed results of the erosion test – P6058 sample**

	Requirements	Test results – P6058
Particles > 0,5 µm	< 60 µg/m <sup>3</sup>	0,011
Particles > 5,0 µm	< 4,0 µg/m <sup>3</sup>	0,006

**Table 5 : Comparison with the requirements – P6058**

The material from the inside surface of the ductwork does not break away, flake off and does not show evidence of delamination or erosion.

**The requirements concerning the maximum particle concentration are fulfilled for the P6058 sample.**

**APPENDIX 3 - RESISTANCE AGAINST PRESSURE TEST**


The pressure test determines the fitness for purpose of the ductboard assembly. A test sample is prepared like it can be seen in Figure 6.

Two typical rectangular section ducts were constructed by the URSA IBERICA AISLANTES SA company and assembled with a peripheral joint. The used internal section is 300 mm \* 300 mm. The connections along the ducts have been made airtight with additional adhesive tape by CETIAT, to keep only the median peripheral joint.

A pressure tap is sealed on the test sample and connected to a manometer. The manometer is checked for zero reading at the beginning and end of each test.

An air supply tap is sealed on the test sample to supply specified air pressure.

Figure 6 shows a sample in test.




**Figure 6 : View of the test facility**

The manufacturer's rated pressure is 800 Pa.

This pressure is gradually reached in a time between 45 and 60 s, and is maintained during 1 min. It is then increased to 2000 Pa (2,5 times 800 Pa), and maintained during 1 h.


### *Detailed results*

As it can be seen on Figure 7, clamps of the peripheral joint did not move during the pressure test, for both samples.




**Figure 7 : View of the peripheral joint after the test (P5858 sample)**

For each sample, it can only be noted that adhesive tape began to peel off at one place (Figure 8 and Figure 9)



**Figure 8 : Adhesive tape begins to peel off – P5858 sample**



**Figure 9 : Adhesive tape begins to peel off – P6058 sample**

**APPENDIX 4 - ARTIGHTNESS TEST**


Tests are made following prEN1507 standard.

The test samples built by URSA IBERICA AISLANTES consist of 7 modules of 1,2 m of length and section of 300 mm × 300 mm.

For each sample :

Ductwork surface area (A) =  $7 \times 1,2 \times 4 \times 0,3 = 10,1 \text{ m}^2$

Total joint length (L) =  $6 \times 4 \times 0,3 + 7 \times 1,2 = 15,6 \text{ m}$



**Figure 10 : Diagram of the samples**

CETIAT closed the ends of each sample with metal sheets.

Table 6 shows the airtightness classification defined in the prEN 1507 draft standard.

Air tightness class	Air leakage limit $\text{l.s}^{-1} \cdot \text{m}^{-2}$	Static gauge pressure limits (Pa)	
		Negative	Positive
A	$0,027 \cdot p_{\text{test}}^{0,65}$	-200	1000
B	$0,009 \cdot p_{\text{test}}^{0,65}$	-500	1000
C	$0,003 \cdot p_{\text{test}}^{0,65}$	-750	1000
D*	$0,001 \cdot p_{\text{test}}^{0,65}$	-750	1000

**Table 6 : Definition of the airtightness classes – prEN1507**

The limit for the positive pressure test is defined by the manufacturer, following the design operating pressure of the ducts.

The limit for the negative pressure test depends of the class to be aimed. Tests are then made until -750 Pa.

**Detailed results – P5858 sample**

Atmospheric pressure : 99300 Pa

Air temperature : 21°C

Wet bulb temperature : 15°C

*Negative pressure*

Measured air leakage	Air density	Air leakage at 20°C and 101325 Pa	Air leakage at 20°C and 101325 Pa	Pressure
m <sup>3</sup> /h	kg/m <sup>3</sup>	m <sup>3</sup> /h	l/s	Pa
4.7	1.17	4.6	1.3	-193
6.2	1.16	6.0	1.7	-312
7.0	1.16	6.8	1.9	-399
7.7	1.16	7.5	2.1	-493
8.5	1.16	8.2	2.3	-598
<b>9.5</b>	<b>1.16</b>	<b>9.1</b>	<b>2.5</b>	<b>-748</b>
10.3	1.16	10.0	2.8	-897

*Positive pressure*

Measured air leakage	Air density	Air leakage at 20°C and 101325 Pa	Air leakage at 20°C and 101325 Pa	Pressure
m <sup>3</sup> /h	kg/m <sup>3</sup>	m <sup>3</sup> /h	l/s	Pa
4.6	1.17	4.5	1.3	197
7.1	1.17	7.0	1.9	401
9.1	1.18	8.9	2.5	592
10.8	1.18	10.6	2.9	791
12.3	1.18	<b>12.1</b>	<b>3.4</b>	<b>1008</b>
13.4	1.18	13.2	3.7	1200

	Air leakage rate (l/s/m <sup>2</sup> )	Air leakage limit class B (l/s/m <sup>2</sup> )	Air leakage limit class C (l/s/m <sup>2</sup> )	Class
-493 Pa	0,21	0,51	0,17	B
-748 Pa	0,25	0,66	0,22	B
1008 Pa	0,33	0,81	0,27	B

### Detailed results – P5858 sample

Atmospheric pressure : 99100 Pa

Air temperature : 23°C

Wet bulb temperature : 13,5°C

#### Negative pressure

Measured air leakage	Air density	Air leakage at 20°C and 101325 Pa	Air leakage at 20°C and 101325 Pa	Pressure
m <sup>3</sup> /h	kg/m <sup>3</sup>	m <sup>3</sup> /h	l/s	Pa
7.1	1.16	6.9	1.9	-204
8.9	1.16	8.5	2.4	-298
10.4	1.15	10.0	2.8	-396
11.8	1.15	11.3	3.1	-497
12.9	1.15	12.4	3.4	-597
14.4	1.15	13.8	3.8	-746

#### Positive pressure


Measured air leakage	Air density	Air leakage at 20°C and 101325 Pa	Air leakage at 20°C and 101325 Pa	Pressure
m <sup>3</sup> /h	kg/m <sup>3</sup>	m <sup>3</sup> /h	l/s	Pa
7.1	1.16	6.9	1.9	197
11.6	1.16	11.2	3.1	394
15.8	1.17	15.4	4.3	599
19.0	1.17	18.5	5.1	790
22.5	1.17	21.9	6.1	992
25.5	1.17	24.9	6.9	1175

	Air leakage rate (m <sup>3</sup> /s/m <sup>2</sup> )	Air leakage limit class B (m <sup>3</sup> /s/m <sup>2</sup> )	Air leakage limit class C (m <sup>3</sup> /s/m <sup>2</sup> )	Class
-497 Pa	0,31	0,51	0,17	B
-746 Pa	0,38	0,66	0,22	B
992 Pa	0,61	0,80	0,27	B


Both samples are in the class B. There is less air leakage for the P6058 sample than for the P5858 sample.

Air leakage comes mostly from the clamp, where the adhesive tape is worn and pierced.


For information, we added new adhesive tape on half of the clamps for the P6058 sample and the air leakage rate was divided by two : 3 m<sup>3</sup>/h for 992 Pa.




**Figure 11 : Leakage flow rate according to the negative pressure – P5858 and P6058 samples**



**Figure 12 : Leakage flow rate according to the positive pressure – P5858 and P6058 samples**



**Figure 13 : View of the test facility**



**Figure 14 : View of the metrology**

## **APPENDIX 5 - WEIGHTED ACOUSTICAL ABSORPTION TEST**

The acoustical absorption characterises the properties of a material composition to convert sound energy into heat thereby reducing the amount of sound energy that can be reflected.

The acoustical absorption tests are made according to ISO 354 standard. Results are treated with the ISO 11654 standard to determine weighted acoustical absorption.

ISO 354 specifies a method of measuring the sound absorption coefficient of acoustical materials used as wall or ceiling treatments, or the equivalent sound absorption area of objects, such as furniture, persons or space absorbers, in a reverberation room.

ISO 11654 specifies a single number rating that can be used to formulate requirements and to describe acoustical properties of sound-absorption products used for routine applications in buildings.




**Figure 15 : View of the testing chamber with diffusers**

There are 7 diffusers in the test chamber (15 m<sup>2</sup>).

The surface of the tested samples is 11,7 m<sup>2</sup>.




**Figure 16 : View of the P5858 sample in test**



**Figure 17 : View of the P6058 sample in test**


### Alpha absorption



**Figure 18 : Alpha absorption for P5858 sample**

The weighted acoustical absorption  $\alpha_p = 0,45$  for the P5858 sample.

### Alpha absorption



**Figure 19 : Alpha absorption for P6058 sample**

The weighted acoustical absorption  $\alpha_p = 0,50M$  for the P6058 sample. The "M" letter indicates that absorption is particularly good at medium frequencies.

The calculation of  $\alpha_p$  does not represent the good acoustical absorption of the microperforated sample. Figure 19 shows that absorption for P6058 sample is really better particularly for the mean frequencies, around 1000 Hz.

The calculated  $\alpha_p$  is not very good because of the less good performance at low frequencies.